

FTR 101.XXX

Raumtemperaturregler Bimetall Unterputz im Flächenschalterrahmen Bimetal room temperature controller for flush installation in a flush mounted switch frame

Sicherheitshinweis!

D

Dieses Gerät darf nur durch eine Elektrofachkraft geöffnet und gemäß dem entsprechenden Schaltbild im Gehäusedeckel / auf dem Gehäuse / in der Bedienungsanleitung installiert werden. Dabei sind die bestehenden Sicherheitsvorschriften zu beachten. Nach der Installation ist der Betreiber, durch die ausführende Installationsfirma, in die Funktion und Bedienung der Regelung einzuführen. Die Bedienungsanleitung muss für Bedien- und Wartungspersonal an frei zugänglicher Stelle aufbewahrt werden.

1. Anwendung

Dieser Raumtemperaturregler wurde speziell für die Regelung oder Überwachung von Temperaturen in Büros, Wohnräumen und Hotels entwickelt und ist geeignet für alle Heizungsarten. Bei elektrischen Fußbodenheizungen ist darauf zu achten, dass die Leistung der Heizung auch bei Dauerbetrieb den Estrich nicht überhitzen kann. Bei Warmwasserheizungen sind auf den Heizausgang max. 10 stromlos geschlossene, oder auf den Kühlungsausgang (Typ .010) max. 5 stromlos offene Ventile anzuschließen. Im Kühlraum sind max. 5 stromlos geschlossenen Ventile auf den Kühlungsausgang oder max. 10 stromlos offene Ventile auf den Heizausgang anzuschließen.

Achtung! Bei dem speziell für 2-Rohr-Klimasysteme entwickelten Reglertyp FTR-101.065, ist die Bedrückung des Heiz-/Kühl-Umschalters auf stromlos geschlossene Ventile ausgelag. An diesen Typ dürfen maximal 5 Ventilantriebe angeschlossen werden. Gegebenenfalls benötigte Temperaturbegrenzungen müssen zusätzlich installiert werden. Für andere, vom Hersteller nicht vorherzusehende Einsatzgebiete, sind die dort gültigen Sicherheitsvorschriften zu beachten. Eignung hierfür siehe Punkt 7. Gewährleistung.

2. Funktionen

Der Raumtemperaturregler erfassst mit einem innenliegenden Bimetallfühler die Raumtemperatur und regelt entsprechend dem eingestellten Sollwert. Die einzelnen Reglertypen unterscheiden sich durch die Ausstattung, wie Schalter „Ein / Aus“ und Lampe rot „Heizen“ (Typ .062), Schalter und Lampe rot „Ein / Aus“ (Typ .073), Schalter „Heizen/Kühlen“ (Typ .065) sowie Schalter „Absenken/Komfort/Automatik“ und Lampe grün „Nachtabsehung“ (Typ .075).

2.1 Thermische Rückführung

Da während des Heiz- oder Kühlvorgangs der Regler die Raumtemperatur erst relativ spät erfassst, wird mittels einer thermischen Rückführung der Regler rechtzeitig zum Ausschalten angeregt und so eine sehr genaue Schaltendifferenz erreicht.

2.2 Bereichseinengung


Mittels der sich unter dem Knopf befindlichen Einstellfahnen kann der Einstellbereich mechanisch begrenzt werden. (siehe Punkt 3.).

2.3 ECO-Betrieb (Nachtabsehung)


Bei Reglern mit ECO-Betrieb (Uhrensymbol im Anschluss-Schaltbild) wird bei Beschalten der Klemme  mit 230 V~ auf eine um ca. 4K geringere Temperatur geregelt.

3. Installation / Montage

Je nach Gerätetyp oder Verpackungsgröße, wird das Gerät entweder geschlossen oder der schnelleren Montage wegen geöffnet geliefert. Das Gerät ist mittels Zwischenrahmen der Schalterhersteller nach DIN 49075 in nahezu alle Schalterprogramme integrierbar. Daraus kann der Auslieferungszustand je nach Bestellangaben mit oder ohne ALRE-Rahmen erfolgen. Bei Mehrfachrahmen ist der Regler immer an unterster Stelle zu montieren. Der Regler ist zur Montage in die UP-Dose bestimmt und darf nicht direkt Wärme- oder Kältequellen ausgesetzt werden. Es ist darauf zu achten, dass der Regler auch rückseitig keiner Fremderwärmung oder -kühlung, z.B. bei Hohlwänden durch Zugluft oder Steigleitungen ausgesetzt wird.



Zum Öffnen des Reglers ist die Schraube nach Abziehen des Einstellknopfes zu lösen und die Reglerkappe inklusive Rahmen abzunehmen. Nach elektrischem Anschluss und Montage in die UP-Dose, ist der Regler in umgekehrter Reihenfolge wieder zu schließen.



Safety information!

GB

No persons other than expert electricians only must open this device in due compliance with the wiring diagram shown in the housing cover / on the housing / represented in the corresponding operating instructions. All expert electricians committed to the execution of such works must comply with the relevant safety regulations currently operative and in force. The company charged with the installation of the device must, after the completion of the installation works, instruct the user of the control system into its functions and in how to operate it correctly. These operating instructions must be kept at a place that can be accessed freely by the operating and/or servicing personnel in charge.

1. Application

This room temperature controller has been especially devised for the control and supervision of temperatures in offices, living spaces and hotels and is suited for the control of all types of heating systems. With electric floor heating systems care must be taken to ensure that the performance of the controlled system cannot, even if the system is operated continuously, result in an overheating of the pavement. With hot water heating systems, no more than 10 normally closed valves must be connected to the heating output and no more than 5 normally open valves to the cooling output (type version .010). With water cooling systems, no more than 5 normally closed valve must be connected to the cooling output and no more than 10 normally closed valves to the heating output.

Caution: The controller model FTR-101.065 has been specially developed for the control of two-pipe climate systems. The imprint on its heating/cooling changeover switch relates to normally closed valves only. No more than 5 valve drives must be connected to it. Where applicable, temperature limiters need to be installed in addition. Regarding other applications not to be foreseen by the manufacturer of this device, the safety standards these applications need to be followed and adhered to. Regarding the aptitude of the device for any such application, please refer to section 7. herein (Warranty).

2. Functional description

The room temperature controller described herein is equipped with an internal bimetal sensor that captures the currently existing room temperature. The device controls the related heating or cooling system in accordance with the adjusted set value. The individual controller models differ by the different components they are endowed with, such as "ON/OFF" switches, red lamps for heating mode indication (type version .062), switches with red "ON/OFF" indicator lamp (type version .073), "heating/cooling" mode changeover switches (type version .065), "temperature decrease / comfort mode / automatic mode" selector switches and green "night temperature decrease mode" indicator lamps (type version .075).

2.1 Thermal recirculation

As, during the heating or cooling procedure, the controller usually captures the actually prevailing room temperature at a rather late point, a thermal recirculation has been realised with the device that enables to excite it early enough with the consequence that a very precise switching difference can be attained.

2.2 Suppression of the setting range


The setting elements (pins) located underneath of the knob enable to delimit the setting range mechanically (see section 3.).

2.3 ECO mode (night temperature decrease mode)


With all controller models that enable to operate in ECO mode (indicated by the clock symbol shown in the connection diagram), the room temperature is decreased by approx. 4K when connecting the 230 V~ power supply to the terminal .

3. Mounting / Installation


The device is, depending on the type version of the device or size of the package used for it, either delivered in closed or, in order to facilitate its fast installation, also in opened condition. The device suits for the integration into almost all DIN 49075 compliant intermediate frames that form part of the different frame lines offered by different producers. This is why the device is, depending on the order specifications, delivered either with or without a genuine ALRE intermediate frame. If using multiple frames, the controller must always be mounted in the lowest position. The controller is determined for installation on an UP box and must not be exposed to any heat or cold sources whatsoever. Also care must be taken to ensure that it is not exposed to the influence of heat or cold sources that warm or cool the device at its back (through air flows in cavity walls or the temperatures radiated by ascending pipelines, f. ex.).



To open the controller, remove the adjusting knob first, then loosen the screw and remove the controller cap. After its electrical connection and installation in the UP box, the closing of the controller takes place in inverse order.




Um den Einstellbereich einzuschränken, wird der sich unter dem Einstellknopf befindliche Stift abgezogen und die Einstelfahnen verstellt (rot für maximal und blau für minimal mögliche Einstellung). Anschließend wird der Stift wieder eingesteckt und somit die Begrenzungen arriert.



4. Technische Daten

Fühlerelement:	Bimetall, Typ 1C
Versorgungsspannung und Schaltspannung:	250V~
Schaltvermögen Öffner:	max. 10(4)A
Schaltvermögen Wechsler:	max. 5A(2)A (beide Kontaktseiten)
Regelbereich:	5 ... 30°C
Schaltdifference:	ca. 0,5K
Skala:	Merkziffernskala (*2 3 • 5 6)
max. zulässige Temperatur-Änderungs geschwindigkeit der Regelstrecke:	4K/h
Schutzart:	IP30 nach entsprechender Montage
Schutzklasse:	II nach entsprechender Montage
max. zulässige Luftfeuchtigkeit:	95%RH, nicht kondensierend
Gehäuse:	Berlin Unterputz
Gehäusematerial und -Farbe:	Kunststoff Polycarbonat (PC), reinweiß (ähnlich RAL 9010)
Approbation:	VDE siehe Geräteaufdruck

The setting pins located underneath of the adjusting knob enable to delimit the setting range by mechanically. To enable this, the adjusting knob must be removed by pulling it off and, after the adjustment of the related pins (end stops, red for max. and blue for min. setting) be put on again in order to lock the limitations.



4. Technical data

Sensing element:	bimetal sensor, type 1C
Supply and switching voltage:	250V~
Switching capacity break contact:	max. 10(4)A
Switching capacity make contact:	max. 5A(2)A (on both contact sides)
Control range:	5 ... 30°C
Switching difference:	approx. 0.5K
Scale:	note numeral scale (*2 3 • 5 6)
Max. admissible temperature changing speed of the controlled system:	4K/H
Degree of protection:	IP30 (after according installation)
Protection class:	II (after according installation)
Max. admissible air moisture:	95% r.h., non condensing
Housing:	design Berlin "UP"
Housing material and colour:	plastic (polycarbonate), pure white (similar to RAL 9010)
Certification:	VDE, see housing imprint



5. Klemmen- und Bediensymbole

Bediensymbole	
I	Ein
0	Aus
⌚	Automatikbetrieb
☀	Komfortbetrieb
🌙	ECO-Betrieb (Nachtabsenkung)
✳	Betriebsart Heizen
✳ (am Schalter)	Betriebsart Kühlen
✳ (an der Skala)	Frostschutzstern (entspricht ca. 5°C)
●	Wohlfühlpunkt (entspricht ca. 20°C)

5. Terminal and control symbols

Control symbols	
I	ON
0	OFF
⌚	Automatic mode
☀	Comfort mode
🌙	ECO mode (night temperature decrease mode)
✳	Heating mode
✳ (at the switch)	Cooling mode
✳ (at the scale)	Frost protection system (equivalent to approx. 5°C)
●	Well-being point (equivalent to approx. 20°C)

6. Maßbild und Anschluss-Zeichnungen / Dimensioned drawing and connection diagrams



FTR101.000

FTR101.002







FTR101.010

FTR101.062

FTR101.065

FTR101.073

FTR101.075



7. Gewährleistung / Warranty

Die von uns genannten technischen Daten wurden unter Laborbedingungen nach allgemein gültigen Prüfvorschriften, insbesondere DIN-Vorschriften, ermittelt. Nur insoweit werden Eigenschaften zugesichert. Die Prüfung der Eignung für den vom Auftraggeber vorgesehenen Verwendungszweck bzw. den Einsatz unter Gebrauchsbedingungen obliegt dem Auftraggeber; hierfür übernehmen wir keine Gewährleistung. Änderungen vorbehalten.

The technical data specified herein have been determined under laboratory conditions and in compliance with generally approved test regulations, in particular DIN standards. Technical characteristics can only be warranted to this extent. The testing with regard to the qualification and suitability for the client's intended application or the use under service conditions shall be the client's own duty. We refuse to grant any warranty with regard thereto. Subject to change without notice.